

Please cite the Published Version

Hunt, JD, Nascimento, A, Zakeri, B, Jurasz, J, Dąbek, PB, Barbosa, PSF, Brandão, R, de Castro, NJ, Leal Filho, W and Riahi, K (2022) Lift Energy Storage Technology: a solution for decentralized urban energy storage. Energy, 254 (Part A). p. 124102. ISSN 0360-5442

DOI: https://doi.org/10.1016/j.energy.2022.124102

Publisher: Elsevier

Version: Published Version

Downloaded from: https://e-space.mmu.ac.uk/630475/

Usage rights: (cc) BY

Creative Commons: Attribution 4.0

Additional Information: This is an Open Access article which appeared in Energy, published by Elsevier.

Enquiries:

If you have questions about this document, contact openresearch@mmu.ac.uk. Please include the URL of the record in e-space. If you believe that your, or a third party's rights have been compromised through this document please see our Take Down policy (available from https://www.mmu.ac.uk/library/using-the-library/policies-and-guidelines)

Energy 254 (2022) 124102

Contents lists available at ScienceDirect

Energy

journal homepage: www.elsevier.com/locate/energy

Lift Energy Storage Technology: A solution for decentralized urban energy storage

Julian David Hunt ^{a, b, *}, Andreas Nascimento ^b, Behnam Zakeri ^a, Jakub Jurasz ^c, Paweł B. Dąbek ^d, Paulo Sergio Franco Barbosa ^e, Roberto Brandão ^f, Nivalde José de Castro ^f, Walter Leal Filho ^g, Keywan Riahi ^a

^a International Institute for Applied Systems Analysis (IIASA), Austria

^c Wrocław University of Science and Technology, Poland

^d Wrocław University of Environmental and Life Sciences, Poland

^e Federal University of Alfenas, Brazil

^f Federal University of Rio de Janeiro, Brazil

^g Hamburg University of Applied Sciences, Germany

ARTICLE INFO

Article history: Received 27 January 2022 Received in revised form 3 April 2022 Accepted 23 April 2022 Available online 29 April 2022

Keywords: Energy storage Gravitational energy storage Decentralized energy storage Grid management Smart grids Ancillary services

ABSTRACT

The world is undergoing a rapid energy transformation dominated by growing capacities of renewable energy sources, such as wind and solar power. The intrinsic variable nature of such renewable energy sources calls for affordable energy storage solutions. This paper proposes using lifts and empty apartments in tall buildings to store energy. Lift Energy Storage Technology (LEST) is a gravitational-based storage solution. Energy is stored by lifting wet sand containers or other high-density materials, transported remotely in and out of the lift with autonomous trailer devices. The system requires empty spaces on the top and bottom of the building. An existing lift can be used to transport the containers from the lower apartments to the upper apartments to store energy and from the upper apartments to the lower apartments to generate electricity. The installed storage capacity cost is estimated at 21 to 128 USD/kWh, depending on the height of the building. LEST is particularly interesting for providing decentralized ancillary and energy storage services with daily to weekly energy storage cycles. The global potential for the technology is focused on large cities with high-rise buildings and is estimated to be around 30 to 300 GWh.

© 2022 The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY licenses (http://creativecommons.org/licenses/by/4.0/).

1. Introduction

Buildings consume around 40% of electricity worldwide [1]. There are several solutions to increase the efficiency of energy services in buildings. However, there is a limited number of solutions for electricity generation in buildings. The existing ones can include solar power generation [2] and energy storage (batteries or small scale pumped-storage [3]). The increasing electricity generation from variable renewable energy (VRE) sources can reduce the dependence on fossil fuels and curtail CO₂ emissions. However, each VRE source requires a supplementary flexibility solution due

E-mail address: hunt@iiasa.ac.at (J.D. Hunt).

to its intermittency [4]. In addition, electricity demand in a building often varies a lot daily and weekly, and during holiday seasons, which increases the interest in storing energy within the building itself.

The energy consumption in elevators is usually 2–10% of the building's total energy consumption [1]. During peak hours, elevators may constitute up to 40% of the building's electricity demand [5]. The estimated daily energy consumption of elevators in New York City is 1945 MWh on weekdays, with a peak demand of 138.8 MW, and 1575 MWh during a weekend, with a peak demand of 106.0 MW [6]. Fig. 1 presents the distribution of buildings heights in New York City and the energy consumed by elevators¹.

https://doi.org/10.1016/j.energy.2022.124102



ScienceDire



^b Federal University of Espírito Santo, Brazil

^{*} Corresponding author.International Institute for Applied Systems Analysis (IIASA), Austria.

¹ For more details on elevator power consumption in New York City, please refer to [6].

^{0360-5442/© 2022} The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY license (http://creativecommons.org/licenses/by/4.0/).



Fig. 1. New York City (a) histogram of buildings clustered by the number of floors, (b) distribution of building types as a function of the number of floors, (c) elevator power consumption by building type during a weekday and (d) during the weekend [6].

Lifts are complex systems that aim to provide quality transport services with the least costs and energy consumption. In one and a half centuries, the speed of elevators has increased 100 times [1]. New technologies and best practices involving motors, regeneration converters, control software, and optimization of counterweights or rope-free lifts can further increase the efficiency of lifts [1].

Lifts are composed of several components, as described in Ref. [7]. To achieve high and smooth acceleration offering highquality transport services and maintaining a high overall energy efficiency, the motors are being built gearless and with regenerative brakes, which generate clean and safe electricity during descents [7]. The high-efficiency permanent-magnet synchronous gearmotor (PMSGM) has been developed for smart elevators. The efficiency of the traditional gear reducers varies between 66% and 76%, which is low. The performance and parameters of the PMSGM motor/generator have efficiencies near 92% [1,8,9]. The gain in efficiency with regenerative braking happens particularly when the elevators travel with the cars fully loaded.

Electrical energy storage (EES) alternatives for storing energy in a building are typically batteries and pumped-hydro storage (PHS) [10-13]. Batteries benefit from an ever-decreasing capital cost [14]. They will probably offer an affordable solution to store energy for intraday and daily energy variations or provide ancillary services to the grid [15-18]. However, the use of batteries to store energy in a weekly cycle might never become economically viable due to the high cost of stored energy (\$/MWh) and in some cases, a high rate of losses and/or self-discharge during the day [19]. Moreover, the large-scale deployment of batteries in mobility applications and power systems raises questions related to the resource availability and sustainability of such heavy use of materials for batteries [20,21].

Pumped hydropower storage (PHS) can store large amounts of energy for weekly, monthly or seasonal cycles in potential energy stored as the mass of water in high elevations [22–26]. PHS plants are the only economically feasible option for relatively large installed storage capacities, i.e., greater than 50 or 100 MW [4,27,28]. This is because the cost of tunnels, pipelines, turbines, and generators per generation capacity will benefit from the economy of scale [29]. For example, if the diameter of the tunnel doubles, it doubles the cost of the tunnel; however, it also quadruples the amount of water that passes through the tunnel and, therefore, also the plant's capacity. Thus for PHS projects, the greater the installed capacity, the cheaper the project's installed capacity (\$/MW), as shown by Ref. [30].

There is a high demand for viable technology in the market that would offer affordable long-term energy storage with a low generation capacity other than H_2 and other synthetic fuels, which suffer from a relatively low AC-to-AC efficiency and high capital cost. This paper argues that this gap could be potentially filled with a novel solution called Lift Energy Storage Technology (LEST). LEST is an EES technology that deploys an existing lift in a high-rise building to elevate a solid mass to the top of the building in the charging mode and to lower the mass generating electricity in the



Step 1: Technology validation

Fig. 2. Lift Energy Storage Technology methodological framework.

discharge mode. Lift technology is very mature and has been applied widely everywhere. The main interference of LEST with the existing technology is that the lift would also be used to generate electricity when lowering the elevation of the mass.

Several companies are investing in gravitational energy storage, a technology for storing potential energy with solid materials at different elevations. Energy Vault offers a head difference by building and dismantling a high tower made of concrete blocks. The disadvantage of this technology is that the head difference between the lower and upper storage sites is relatively low; it also requires great precision when constructing the 'concrete tower', which can deteriorate in time [31,32]. Another solution proposes using existing mine shafts with large heads to store potential energy [33–37]. There are also proposals for using train tracks to carry a concrete mass from the lower to the upper storage site [38–41]. Apart from having to construct rail tracks, the weight of the train itself is almost equal to the weight of the concrete block, which results in larger energy losses. The slope of the train tracks also reduces the total power output compared to a vertical descent, as proposed in this paper [42]. A similar alternative that has received much attention lately is the possibility of electricity generation with Electric Truck Hydropower [43]. Reference [44] presents a review of EES technologies, including the gravel energy storage technology [45], and others [46], which are similar to the technology presented in this paper.

To fill this existing gap for a decentralized energy storage solution in urban environments with weekly cycles, this paper proposes LEST as an innovative energy storage approach. It also shows that gravitational energy storage technologies are particularly interesting for long-term energy storage (weekly storage cycles) in systems with small energy storage demand. Furthermore, the LEST design proposed in this paper has been developed by the authors. The remaining content of this paper is structured as follows. Section 2 discusses the methods, while Section 3 presents the results. Section 4 discusses the proposed technology, and Section 5 concludes the paper.

2. Methodology

Fig. 2 presents the methodological framework implemented to assess the LEST proposed in this paper. Step 1 consists of validating the technology, analyzing the overall contribution of elevators in the building, describing the components and the efficiency of conventional lifts, and defining the proposed LEST. Step 2 consists of developing the LEST, finding its niches for energy storage services, such as installed capacity and storage cycles, proposing different types of lower and upper storage sites, and analyzing different storage material densities and costs and other system components. Step 3 consists of estimating the global potential for LEST.

2.1. Lift Energy Storage Technology (LEST)

LEST links two storage sites, one located on the bottom of a tall building (lower storage site) and the other at the top of the same

Table 1	
---------	--

Possible alterna	tives for the	upper and	lower	storage	sites.

Storage site	Туре	Description
Upper and Lower	Empty apartments	Empty apartments can be accessed autonomously by the transport device carrying the containers, which also deposits them
	Occupied apartments	Utilized apartments can be accessed autonomously by the transport device carrying the containers, which can also deposit them in a way that does not disturb the function of the apartment.
	Corridors	If the use of corridors does not impede the passage of people, corridors can be used to store the containers.
	Swimming pools	In this case, the containers are filled with water. A small pump will be required to pump water from the pool to the container.
Upper	Building roof	The building roof often has spare space that can be used to store the containers. Note that the top section of the roof cannot be accessed in some buildings because the lift does not reach it.
	Tuned mass damper	A tuned mass damper is a heavy object on the top of high buildings that absorbs vibrations from high wind or earthquakes. The autonomous trailers with filled containers can move to the top of the tower to provide tuned mass damper services.
Lower	Garage	Vacant parking lots on the building can be used as a containers storage site.
	Hall	The hall is usually an area with plenty of spare space that can be used to store the containers.



Fig. 3. Lift Energy Storage Technology (LEST) (a) system components, (b) not changed and (c) fully charged building, (d) operating on energy storage, (e) electricity generation, or (f) ancillary services mode.

building (upper storage site). Energy is stored as potential energy by elevating storage containers with an existing lift in the building from the lower storage site to the upper storage site. Electricity is then generated by lowering the storage containers from the upper to the lower storage site. An example of the proposed arrangement is presented in Table 1. The upper and lower storage sites are described in Fig. 3a,b,c. The loading and unloading of the containers into the lift is performed by an autonomous trailer that retrieves the containers from the storage site (lower or upper), enters the lift, moves up or down, leaves the lift and deposits the container in the other storage site (upper or lower, respectively) (Fig. 3d and e and Fig. 4a and b). The autonomous trailer has visual sensors to avoid hitting people when entering or leaving the lift and carrying the containers around the building (Fig. 4c). As the energy



Fig. 4. (a) Occupied apartments with 36 storage containers, (b) empty apartments with 573 storage containers, (c) autonomous trailer and storage container.

requirements to move the containers horizontally with the autonomous trailer are small, they were not included in this estimate. The horizontal energy consumption will depend on the trailer, the wheels, and the flooring. Carpet flooring will significantly increase horizontal energy consumption. The storage system will record the position of the containers and run software to optimize the available storage capacity in the upper and lower storage sites. The building administration can choose to have the system operate only during periods of low lift demand to minimize the impact of the LEST system's operation on the building occupants. The lift system can vary the speed of the lift depending on the energy storage power requirements. If the power requirements are high, the lift can increase its speed; however, this will reduce the system's overall efficiency. As shown in Fig. 3f, when the lifts are not being used, such as during the night, the autonomous trailers can fill the lift with containers, and the lift can be used to provide ancillary services to the power grid by lifting and descending the mass continuously on grid requirements.

The amount of stored energy is represented by Eq. (1), which is proportional to the stored mass, the height difference between the lower and higher storage sites and the system's overall efficiency. As the head difference and the storage mass increase, the amount of energy stored in the system increases.

$$E = m \times h \times g \times e \tag{1}$$

where, *E* is the energy stored in the containers (J), *m* is the mass of the containers (kg), *h* is the average height difference between the upper and lower storage sites (m), *g* is the acceleration of gravity (m/s^2) , *e* is the efficiency of the lift to move the containers up and down, assumed to be 80% based on [47].

The power generated by the LEST plant can be calculated with Eq. (2), where the power is equal to the energy stored in the sand or gravel divided by the time it takes to lower it. For example, the system will generate more power if the sand or gravel is lowered quickly.

$$P = \frac{E}{T}$$
(2)

where, P is the power generated by the LEST system (W), T is the time taken for the sand or gravel to move from the upper to the lower storage site (s). Conventional lifts are designed with a power capacity presented in Fig. 5.



Fig. 5. Lift motor usual power consumption. Updated for quality based on Ref. [48].

Energy 254 (2022) 124102



Fig. 6. Density and costs comparison of different materials [49-53].

3. Results

The storage media used in the proposed design will depend on the available space and the returns from the energy storage service. For example, if the cost of storage space is low, then a mixture of sand and water could be a good solution. On the other hand, if the cost of storage space is high, then materials with higher density might be applied. The density and the costs of several storage media have been compared and presented in Fig. 6 [49–53].

Table 2 presents a comparison of different operation arrangements for LEST, assuming systems with 5000 or 50,000 storage containers with dimensions of 0.5 \times 0.5 \times 2 m, filled with wet desert sand with a density of 2000 kg/m³ and weight of 1 ton (the usual weight limit of lifts are shown in Fig. 5). The number of storage containers varies significantly with the ceiling bearing capacity of the building, further discussed in the discussion section. The storage cycle in days is estimated by assuming an average power generation capacity of 30 kW in the buildings' lifts (0.545/ 24/0.03 = 0.76). The generation capacity factor of the lift is low, as half of the time, the lift will be storing energy and the other half generating electricity. Also, during electricity generation mode, the lift must move up and down to generate electricity. In other words, the lift goes up twice and down twice in a storage cycle. Assuming the lift operates 70% of the time storing energy, the capacity factor of the system is 17.5%. A building with 5000 containers and a 50 m average height difference has an energy storage capacity of 545 kWh (5000 \times 50 \times 0.8 \times 9.81 \times 1000/1000/60/60 = 545 kWh), which is equivalent to the energy storage of an electric truck [54]. Note that the number of lifts in the building can increase significantly if the lifts are rope-free, as described in the discussion section. A LEST with a higher average height difference will offer a higher potential for energy storage and a longer storage cycle.

As Table 2 depicts, different operational arrangements could result in energy storage cycles of a day, weeks, or a month. The LEST

Table 2		
Comparison of different	arrangements for LEST.	

Storage containers (tons)	Average height difference (m)	Long-term energy storage (MWh)	Storage cycle (Days)
5000 50,000	50 100 300 50 100 300	0.55 1.09 2.18 5.45 10.90 21.80	0.76 1.51 3.03 7.57 15.14 30.28



Fig. 7. A proposed operational scenario for LEST to store offshore wind power near New York City, USA. (a) Estimated average lift usage in the Empire States Building during the week [56], (b) proposed location of the offshore wind power plant [55], (c) wind power, electricity demand and energy losses (in GW), (d) energy storage (GWh) energy losses in (GW).

design and operation should focus on long-term storage cycles (weekly or monthly) since batteries can provide short-term energy storage more reliably, cheaply, and efficiently. However, if the demand mini grid's demand exceeds its peak generation capacity or if there is an excess of electricity generation in the grid, which the batteries are not able to store, the LEST could be used to complement the short-term energy storage requirements of the system.

With the intent of reproducing the operational scenario of LEST. we proposed the use of an offshore wind power plant near New York City at 40.4685 latitude and -73.7722 longitude [55], presented in Fig. 7b, with an installed capacity of 1 GW to supply the demand for electricity in tall buildings in New York City, as shown in Fig. 7c. The desired electricity generation resulting from the combined operation of the off-shore wind power plant and the LEST systems consists of the average wind power generation of one week ahead before the hour under analysis. The wind generation profile of the location uses data from the Renewable Ninja site [55]. Fig. 7a shows the visitor frequency in the Empire States building during the week. This is used to estimate when the lifts are available to be used to store energy. However, as the scenario intends to test for long-term energy storage, the daily variation in energy demand is assumed to be balanced with an auxiliary battery system in the building. The LEST system proposed has a storage capacity of 30 GWh and an initial charge of 15 GWh. To reach this storage capacity, 2752 buildings with 50,000 storage containers, each with an average height difference of 100 m would be required. As shown in Fig. 7d, the LEST operation focuses on storing energy mainly in weekly cycles, as it is designed to operate. Fig. 7c shows energy losses because the energy storage system does not have enough storage capacity to store all excess offshore wind generation. These offshore wind power curtailments are only equivalent to 2% of the total offshore wind power generation.

This paper assumes that the lift installed already has regenerative braking capabilities and the cost for renting the space to store the containers in the upper and lower storage sites is zero. Thus, the only cost requirements are the containers, the material selected to increase the mass of the containers, and the autonomous trailers (Table 3). The building used to exemplify the cost of the system has 5000 storage containers, with an average height difference of 100 m. The cost for energy storage is estimated at 64 USD/kWh. The higher the height difference between the lower and upper storage sites, the cheaper it is to store energy with LEST. Another benefit of LEST is that the lifetime of the container and material (79% of the total cost) is longer than 30 years. The lifetime of the autonomous trailer (21% of the total cost) is 5 years.

4. Discussion

This paper argues that LEST could fill the gap for decentralized energy storage technologies with weekly energy storage cycles. See Fig. 8 for LEST with MGES [58], batteries, PHS, ammonia and

Table 3
Cost estimate for LEST.



Energy 254 (2022) 124102



Fig. 8. Comparative illustration of long-term energy storage technologies (LES, PHS, hydrogen and ammonia) and short-term energy storage (batteries), showing their respective energy storage cycle and installed capacities.

hydrogen. This figure focuses on long-term energy storage solutions [59] and the limits to batteries for short energy solutions. For more details on technologies with short-term storage cycles, refer to Refs. [60-66]. The results can be useful for decision makers and energy planners to understand the possible cost-benefits of this storage system compared to other alternatives.

A significant limitation for LEST, which has not been considered in this work, is the ceiling bearing capacity of the building. Buildings and their floors are designed to serve specific purposes. If the purpose of a given building is defined, engineers will follow a building code that will specify requirements regarding, for example, the floor load capacity. This is usually presented in pounds per square foot or kilograms per square meter. It is rather unlikely that buildings in the past have been designed with the idea that they might serve as energy storage facilities in the future. In this work, an assumption was made that the floor load capacity is sufficient to bear the additional weight of the storage blocks in each building. For implementation purposes, it is mandatory to evaluate the local potential by considering the ceiling bearing capacity of the building.

To minimize swaying, developers put giant counterweights called tuned mass dampers (TMD) near the top of skyscrapers. A TMD is a giant ball made of steel or concrete that weighs anywhere from 300 to 800 tons, and it's usually suspended in the building using springs and pistons. The autonomous trailers with containers also function as a tuned mass damper, moving from one side to the other to counterbalance the tower's movement in high winds or during an earthquake. As a high-rise building does not support 500 trailers for LEST, autonomous trailers from surrounding buildings that do not have issues with high wind speeds or earthquakes can move to a nearby tall building to provide tuned mass damper

Туре	Description	Cost
Container	Containers with $0.5 \times 0.5 \times 2$ m dimensions used to store the weight material. The cost of each container is 10 USD. 5000 containers cost 50,000 USD	t 50,000 USD
Material	The material selected for energy storage is desert sand and water, with a cost of 1 USD/ton at the cost of 5000 USD [53].	5000 USD
Autonomous trailer	The system is assumed to have 10 autonomous trailers. Each trailer costs 1500 USD [57].	15,000 USD
Total cost	Assuming 5000 containers with an average generation head of 100 m, the cost of the LEST energy storage system is 70,000 USD.	70,000 USD
Energy storage costs	The energy storage cost is 70,000 USD and the storage capacity of 1090 kWh. This results in a cost of 64 USD/kWh. Battery costs are 120 USD/kWh. Varying the average height different from 300 to 50, the storage cost varies from 21 to 128 USD/kWh.	/ 64 USD/ kWh



Fig. 9. (a) Examples of tuned mass dampers in high-rise buildings [68], (b) world map of the number of buildings higher than 250 m [69].

service. Fig. 9a presents examples of tuned mass dampers in highrise buildings. Fig. 9b is a world map with the number of buildings higher than 250 m in a city. LEST is also particularly interesting in China ghost towns. There are several ghost towns where the lifts could be used as energy storage devices. A review of ghost cities in China can be seen in Ref. [67]. In some cases, the investors do not rent empty apartments because they want to be flexible to sell the flat any time they get a good price. So, LEST can be a good application for such empty flats.

ThyssenKrupp developed the Multi elevator, which does not use ropes (Fig. 10). Instead, it uses magnetic force to raise and lower the lifts [70,71]. This allows the lift to move vertically, horizontally and diagonally [72]. It is particularly interesting for high-rise buildings because several lifts can travel up or down simultaneously in the

same shaft. This significantly reduces the number of shafts required in the building, increasing by up to 50% the space available for residential or office space in the building. This technology is particularly interesting for LEST because: (i) as there are several lifts in the same shaft, the acceleration and speed of the lift are significantly reduced, which increases the overall efficiency of the system (ii) the high number of lifts being raising or lowered at the same time provides a relatively constant supply of electricity, (iii) eliminating the ropes and counterweights of conventional elevators also decreases the mass of the elevator by 50%, further increasing the efficiency of the system [73].

The global potential of LEST can be estimated considering account the existing buildings. We have combined the available online information regarding high-rise buildings' location and height

Energy 254 (2022) 124102



Fig. 10. ThyssenKrupp Multi elevator, the first rope-free elevator globally [74].

from the following organizations [75,76]. In our analysis, only buildings with heights exceeding 50 m were considered. The database starts with Burj Khalifa in Dubai (828 m) and ends with Wills Eye Hospital Walnut Towers in Philadelphia (53.25 m). In total, the database consists of 22,585 buildings distributed globally. Fig. 11 presents the spatial (regions) and height class distribution of buildings within the mentioned database. The mean height of considered buildings is ~120 m, and in general, the largest number of buildings can be found in North America and Asia. The number of buildings is slightly lower than in the considered database as some countries are not included in none of the mentioned regions.

To evaluate the global potential, we have followed the procedure described in Section 2. We made a conservative assumption that each building could withstand (both in terms of space and structure) the mass of 5000 containers. It has also been assumed that the average height is equal to the building height — in some cases, it might lead to an overestimation as some buildings have tall spires not suitable as an upper storage site. At the same time, our calculations neglect the potential increase in average height if deep basements are used as lower storage sites. The results are presented in Fig. 12. The coordinates of buildings have been rounded up to the

North America	3152	2396	670	178	44	17	8	-	3000
Western Europe	1191	464	121	23	7	1	0		÷
Pacific OECD	857	575	295	60	14	2	0		2500
Central and Eastern Europe	113	57	7	3	0	0	0		
Former Soviet Union	616	218	40	8	3	4	3		2000 4
Centrally Planned Asia and China	912	1241	1529	514	148	58	32	-	1500 g
South Asia	38	92	75	14	2	0	0		ildin
Other Pacific Asia	326	654	530	190	40	9	5	-	1000 0
Middle East and North Africa	220	440	237	91	46	18	15		
Latin America and the Caribbean	2366	869	149	34	6	1	0	-	500 Z
Sub-Saharan Africa	57	78	8	3	0	0	0		0
	50-100	101-150	151-200	201-250	251-300	301-350	350+		0

Fig. 11. Number of buildings (colorbar) with specific heights (horizontal axis - ranges are in meters) in selected regions (vertical axis). Regions and countries belonging to them are based on [77].



Fig. 12. Lift energy storage technology - global potential.

closest integer and grouped. Hence buildings near each other are presented together. The global potential was found to be 29.2 GWh, which is rounded to 30 GWh in this paper. Assuming that 50,000 containers can be stored in the buildings, this global potential rises to 300 GWh. The storage potential is proportional to the building height, hence the earlier mentioned Burj Khalifa could potentially store 9 to 90 MWh. The LEST storage potential in the USA sums up to 6.5 to 65 GWh and to 7.3 to 73 GWh in China.

Future directions for the further development of LEST are: (i) run experiments on an existing building with regenerative braking lifts to estimate the efficiency of LEST with different motor/generators and operational modes, such as acceleration and speed, (ii) implement LEST in a building to reduce the overall electricity costs of the building, or store energy from intermittent renewable energy sources, (iii) analyses the benefits and challenges of providing decentralized ancillary services with LEST, (vi) compare LEST with flywheels, (v) design buildings from scratch to optimize their use for energy storage with LEST.

5. Conclusion

This paper concludes that Lift Energy Storage Technology could be a viable alternative to long-term energy storage in high-rise buildings. LEST could be designed to store energy for long-term time scales (a week) to generate a small but constant amount of energy for a long time. This small but constant electricity generation could be combined with other storage technologies, such as batteries, to balance the short-term variations of electricity demand, solar and wind generation.

This paper estimates the cost of installed capacity energy storage cost of LEST to be 62 USD/kWh, assuming an average height difference between the upper and lower reservoirs of 100 m. The cost of LEST with an average height difference of 300 m is 21 USD/ kWh, whereas an average height difference of 50 m costs 128 USD/ kWh. This is half of the cost of storing energy with batteries. The power generation will depend on the existing numbers of lifts in the considered buildings. The technical lifetime of the system can vary from 20 to 30 years. The higher the height difference between the lower and upper storage sites, the lower the project's cost. LEST systems are particularly interesting in buildings with rope-free elevators, and they can also provide tuned mass damper services on the top of very high buildings.

LEST systems are particularly interesting during the night when most lifts are not being used, as the autonomous trailers can continue to fill the lifts with containers to provide ancillary services to the power grid. This is particularly interesting because the demand for ancillary services will increase with the increase in solar and wind power generation, the demand for ancillary services will increase. Having ancillary solutions close to the final demand significantly optimizes frequency and load balancing, improving the quality of the electricity supplied by the grid.

The global storage potential for the technology varies from 30 to 300 GWh, mainly in metropolitan areas with tall buildings, such as New York, Chicago, Philadelphia, Seattle, Los Angeles, Hawaii and Toronto in North America, Dubai and Doha in the Middle East, Beijing, Shanghai, Hong Kong, Tokyo, Kuala Lumpur and Singapore in Asia, and Sydney and Melbourne in Australia. Even though small islands in the Caribbean, Indonesia, the Philippines, and the Pacific Islands don't usually have very many high-rise buildings, these would be more favorable locations for LEST, due to their higher electricity costs and smaller energy storage demand. LEST can serve as a decentralized urban energy storage solution to balance weekly variations in electricity supply from wind and solar sources and demand variations.

Author contributions

Conceptualization, J.H., J.J.; methodology, B.Z., A.N; formal analysis, P·B.; investigation, R.B; data curation, P.D.; writing—original draft preparation, J.H.; writing—review and editing, J.J.; visualization, J.H.; project administration, W·F., N·C., K.R; funding acquisition, A.N.; resources, K.R.; software, P.D. All authors have read and agreed to the published version of the manuscript.

Declaration of competing interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Acknowledgements

This research was funded by the National Agency of Petroleum, Natural Gas and Biofuels(ANP), the Financier of Studies and Projects(FINEP) and the Ministry of Science, Technology and Innovation(MCTI) through the ANP Human Resources Program for the Oil and Gas Sector Gas – PRH-ANP/MCTI, in particular, PRH-ANP 53.1, for all the financial support received through the grant.

References

- [1] Al-Kodmany K. Tall buildings and elevators: a review of recent technological advances. Buildings 2015;5:1070–104. https://doi.org/10.3390/ buildings5031070.
- [2] Shafique M, Luo X, Zuo J. Photovoltaic-green roofs: a review of benefits, limitations, and trends. Sol Energy 2020;202:485–97. https://doi.org/10.1016/ j.solener.2020.02.101.
- [3] Jurasz J, Piasecki A, Hunt J, Zheng W, Ma T, Kies A. Building integrated pumped-storage potential on a city scale: an analysis based on geographic information systems. Energy 2022;242:122966. https://doi.org/10.1016/ j.energy.2021.122966.
- [4] Zakeri B, Syri S. Electrical energy storage systems: a comparative life cycle cost analysis. Renew Sustain Energy Rev 2015;42:569–96. https://doi.org/10.1016/ j.rser.2014.10.011.
- [5] Nemeth B. Energy-efficient elevator machines. TX, USA: Frisco; 2011.
- [6] Tukia T, Uimonen S, Siikonen M-L, Donghi C, Lehtonen M. Modeling the aggregated power consumption of elevators – the New York city case study. Appl Energy 2019;251:113356. https://doi.org/10.1016/j.apenergy.2019.113356.
- [7] ABCO Elevator. Traction elevators, vol. 101; 2021. https://abcoelevator.com/ elevator-types-components/traction-elevators-101/.
- [8] Hwang J, Liu C, Chen P. Design of permanent-magnet synchronous gear motor with high efficiency for elevators. IEEE Third Int. Conf. Sustain. Energy Technol. 2012:205–10. https://doi.org/10.1109/ICSET.2012.6357399. 2012.
- [9] Mohaney S, Shah M. Emerging trends in vertical elevating system. 2015.
- [10] Groppi D, Garcia D, Basso G, Cumo F, De Santoli L. Analysing economic and environmental sustainability related to the use of battery and hydrogen energy storages for increasing the energy independence of small islands. Energy Convers Manag 2018;177:64–76.
- [11] Hunt JD, Zakeri B, Leal Filho W, Schneider PS, de Assis Brasil Weber N, Vieira LW, et al. Swimming pool thermal energy storage, an alternative for distributed cooling energy storage. Energy Convers Manag 2021;230:113796. https://doi.org/10.1016/j.enconman.2020.113796.
- [12] Hunt JD, Weber N de AB, Zakeri B, Diaby AT, Byrne P, Filho WL, et al. Deep seawater cooling and desalination: combining seawater air conditioning and desalination. Sustain Cities Soc 2021;74. https://doi.org/10.1016/ j.scs.2021.103257.
- [13] Hunt JD, Zakeri B, Nascimento A, Garnier B, Pereira MG, Bellezoni RA, et al. High velocity seawater air-conditioning with thermal energy storage and its operation with intermittent renewable energies. Energy Effic 2020;13: 1825–40. https://doi.org/10.1007/s12053-020-09905-0.
- [14] Schmidt O, Melchior S, Hawkes A, Staffell I. Projecting the future levelized cost of electricity storage technologies. Joule 2019;3:81–100.
- [15] Yang Y, Bremner S, Menictas C, Kay M. Battery energy storage system size determination in renewable energy systems: a review. Renew Sustain Energy Rev 2018;91:109–25.
- [16] Lorenzi G, da Silva Vieira R, Silva C, Martin A. Techno-economic analysis of utility-scale energy storage in island settings. J Energy Storage 2019;21: 691–705.
- [17] Lazaroiu G, Ciupageanu D. Multi-Criteria Decision Making in sustainable renewable energy systems. Int. Multidiscip. Sci. GeoConference 2019;SGEM2019.
- [18] Ferreira HL, Garde R, Fulli G, Kling W, Lopes JP. Characterisation of electrical

energy storage technologies. Energy 2013;53:288-98. https://doi.org/ 10.1016/j.energy.2013.02.037.

- [19] Hajiaghasi S, Salemnia A, Hamzeh M. Hybrid energy storage system for microgrids applications: a review. J Energy Storage 2019;21:543–70.
- [20] Wadia C, Albertus P, Srinivasan V. Resource constraints on the battery energy storage potential for grid and transportation applications. J Power Sources 2011;196:1593–8.
- [21] Taibi E, del Valle C, Howells M. Strategies for solar and wind integration by leveraging flexibility from electric vehicles: the Barbados case study. Energy 2018;164:65–78. https://doi.org/10.1016/j.energy.2018.08.196.
- [22] Hunt JD, Freitas MAVD, Pereira Junior AO. A review of seasonal pumpedstorage combined with dams in cascade in Brazil. Renew Sustain Energy Rev 2017;70. https://doi.org/10.1016/j.rser.2016.11.255.
- [23] Hunt JD, Falchetta G, Parkinson S, Vinca A, Zakeri B, Byers E, et al. Hydropower and seasonal pumped hydropower storage in the Indus basin:pros and cons. J Energy Storage 2021;41:102916. https://doi.org/10.1016/j.est.2021.102916.
- [24] Hunt J, Byers E, Wada Y, Parkinson S, Gernaat D, Langan S, et al. Global resource potential of seasonal pumped-storage for energy and water storage. Nat Commun 2020;11. Article number: 947.
- [25] Hunt JD, Freitas MAV, Pereira Junior AO. Enhanced-Pumped-Storage: combining pumped-storage in a yearly storage cycle with dams in cascade in Brazil. Energy 2014;78. https://doi.org/10.1016/j.energy.2014.10.038.
- [26] Hunt JD, Guillot V, Freitas MAV de, Solari RSE. Energy crop storage: an alternative to resolve the problem of unpredictable hydropower generation in Brazil. Energy 2016;101:91–9. https://doi.org/10.1016/j.energy.2016.02.011.
- [27] Jülch V. Comparison of electricity storage options using levelized cost of storage (LCOS) method. Appl Energy 2016;183:1594–606.
- [28] Hunt JD, Zakeri B, Lopes R, Barbosa PSF, Nascimento A, Castro NJ de, et al. Existing and new arrangements of pumped-hydro storage plants. Renew Sustain Energy Rev 2020;129:109914.
- [29] Hunt JD, Zakeri B, Nascimento A, Brandão R. 3 pumped hydro storage (PHS). In: Letcher TMBT-SE. Second E. Elsevier; 2022. p. 37–65. https://doi.org/ 10.1016/B978-0-12-824510-1.00008-8.
- [30] Kapila S, Oni A, Kumar A. The development of techno-economic models for large-scale energy storage systems. Energy 2017;140:656–72.
- [31] Energy Vault. 2019. https://www.energyvault.com/.
- [32] Rodrigues EMG, Godina R, Santos SF, Bizuayehu AW, Contreras J, Catalão JPS. Energy storage systems supporting increased penetration of renewables in islanded systems. Energy 2014;75:265–80. https://doi.org/10.1016/ j.energy.2014.07.072.
- [33] Gravitricity. Fast, versatile energy storage. 2019.
- [34] Gravity Power. Grid scale energy storage. 2019.
- [35] Berrada A, Loudiyi K, Zorkani I. System design and economic performance of gravity energy storage. J Clean Prod 2017;156:317-26. https://doi.org/ 10.1016/j.jclepro.2017.04.043.
- [36] Heindl-Energy. Gravity Storage 2019. https://heindl-energy.com/.
- [37] Tarigheh A. Mater thesis: gravity power module. 2014. Delft.[38] Powell J, Danby G, Coullahan R, Griffis FH, Jordan J. Maglev energy storage and
- the grid. Adv. Energy Conf., New York: [n.d].
- [39] Bottenfield G, Hatipoglu K, Panta Y. Advanced rail energy and storage : AAnalysis of potential implementations for the state of West Virginia. North Am. Power Symp. NAPS; 2018. https://doi.org/10.1109/NAPS.2018.8600665. 2018, 2019.
- [40] Cava F, Kelly J, Peitzke W, Brown M, Sullivan S. Chapter 4 advanced rail energy storage: green energy storage for green energy. In: Letcher TM, editor. Storing energy. Oxford: Elsevier; 2016. p. 69–86. https://doi.org/10.1016/ B978-0-12-803440-8.00004-X.
- [41] Moazzami M, Moradi J, Shahinzadeh H, Gharehpetian GB, Mogoei H. Optimal economic operation of microgrids integrating wind farms and advanced rail energy storage system. Int J Renew Energy Resour 2018;18.
- [42] Newbery D. Shifting demand and supply over time and space to manage intermittent generation: the economics of electrical storage. Energy Pol 2018;113:711–20. https://doi.org/10.1016/j.enpol.2017.11.044.
- [43] Hunt J, Jurasz J, Zakeri B, Nascimento A, Cross S, Caten C, et al. Electric Truck Hydropower, a flexible solution to hydropower in mountainous regions. Energy 2022;248:123495. https://doi.org/10.1016/j.energy.2022.123495.
- [44] Aneke M, Wang M. Energy storage technologies and real life applications a state of the art review. Appl Energy 2016;179:350–77. https://doi.org/ 10.1016/j.apenergy.2016.06.097.
- [45] Sandru O. Gravel energy storage system funded by Bill Gates. Green Optimist 2012. https://www.greenoptimistic.com/gravel-energy-storage/.
- [46] Hunt JD, Zakeri B, de Barros AG, Filho WL, Marques AD, Barbosa PSF, et al. Buoyancy Energy Storage Technology: an energy storage solution for islands, coastal regions, offshore wind power and hydrogen compression. J Energy Storage 2021;40:102746. https://doi.org/10.1016/j.est.2021.102746.
- [47] Nipkow J, Schalcher M. Energy consumption and efficiency potentials of lifts. 2006. Zurich.
- [48] Electrical Know-How. Vertical Transportation Design and Traffic Calculations n.d. http://www.electrical-knowhow.com/2019/06/How-To-Size-The-Elevator-Motor-KW.html.
- [49] Kremer G, Chiu M-C, Lin C-Y, Gupta S, Claudio D, Thevenot H. Application of axiomatic design, TRIZ, and mixed integer programming to develop

innovative designs: a locomotive ballast arrangement case study. Int J Adv Manuf Technol 2012;61. https://doi.org/10.1007/s00170-011-3752-1.

- [50] Almubarak A, Abuhaimed W, Almazrouee A. Corrosion behavior of the stressed sensitized austenitic stainless steels of high nitrogen content in seawater. Int J Electrochem 2013;2013. https://doi.org/10.1155/2013/970835.
- [51] Wuxi Zhonglian Yongsheng Special Steel Co. L. Factory bulk purchase cast iron ms 40mn2 round steel bar, Alibaba. 2021. https://www.alibaba.com/productdetail/Cast-Iron-Bar-Factory-Bulk-Purchase_1600349507806.html? spm=a2700.7735675.normal offer.d image.4ca24daddkvfoT&:s=p.
- [52] Shandong Haihengxin Metal Material Co. L. Factory supply 8Pb 99.994% purity lead sheet lead plate China wholesale. Alibaba. 2021. https://www.alibaba.com/product-detail/Lead-Lead-Sheet-Factory-Supply-8Pb_1600211791769.html?spm=a2700.galleryofferlist.normal_offer.d_title. 64561db3esa08G&:s=p%0A%0Ahttps://www.statista.com/statistics/219381/sand-and-gravel-prices-in-the-us/.
- [53] Cairo fresh for import & export. River sand. 2019. Alibaba.
- [54] Tanvir S, Un-Noor F, Boriboonsomsin K, Gao Z. Feasibility of operating a heavy-duty battery electric truck fleet for drayage applications. Transport Res Rec 2020;2675:258-68. https://doi.org/10.1177/0361198120957325.
- [55] ninja Renewables. Welcome to renewables. ninja; 2019. https://www. renewables.ninja/.
- [56] Google Maps. Empire state building. Google; 2022. https://www.google.com/ maps/place/Empire+State+Building.
- [57] EVER-POWER INDUSTRY PTE. LTD. AGV robot warehouse QR code platform mobile with picking arm autonomous holder New Technical Fast Speed Warehouse Trackless Slam. Alibaba; 2022. https://www.alibaba.com/productdetail/AGV-robot-warehouse-QR-code-platform_1700000642488.html? spm=a2700.galleryofferlist.normal_offer.d_title.23e44b22knlROK.
- [58] Hunt JD, Zakeri B, Falchetta G, Nascimento A, Wada Y, Riahi K. Mountain Gravity Energy Storage: a new solution for closing the gap between existing short- and long-term storage technologies. Energy 2020;190:116419. https:// doi.org/10.1016/j.energy.2019.116419.
- [59] Wijayanta AT, Oda T, Purnomo CW, Kashiwagi T, Aziz M. Liquid hydrogen, methylcyclohexane, and ammonia as potential hydrogen storage: comparison review. Int J Hydrogen Energy 2019;44:15026–44. https://doi.org/10.1016/ j.ijhydene.2019.04.112.
- [60] International Electrotechnical Commission. Electrical energy storage. Geneva: White Paper; 2011.
- [61] Renewable Energy Association. Energy storage in the UK: an overview. 2016. London.
- [62] Akhil A, Huff G, Currier A, Kaun B, Rastler D, Chen S, et al. DOE/EPRI 2013 electricity storage handbook in collaboration with NRECA. 2013. Albuquerque.
- [63] World Energy Council. World energy resources. London: E-Storage; 2016.
- [64] Luo X, Wang J, Dooner M, Clarke J. Overview of current development in electrical energy storage technologies and the application potential in power system operation. Appl Energy 2015;137:511–36.
- [65] International Energy Agency. Technology roadmap: hydrogen and fuel cells. 2015. Paris.
- [66] Hunt J, Byers E, Riahi K, Langan S. Comparison between seasonal pumpedstorage and conventional reservoir dams from the water, energy and land nexus perspective. Energy Convers Manag 2018;166:385–401.
- [67] Jin X, Long Y, Sun W, Lu Y, Yang X, Tang J. Evaluating cities' vitality and identifying ghost cities in China with emerging geographical data. Cities 2017;63:98–109. https://doi.org/10.1016/j.cities.2017.01.002.
- [68] Radmard Rahmani H, Könke C. Seismic control of tall buildings using distributed multiple tuned mass dampers. Adv Civ Eng 2019;2019:6480384. https://doi.org/10.1155/2019/6480384.
- [69] CTBUH Journal. Tall buildings in numbers. 2018.
- [70] Ishimaru S, Yamaguchi S. A simplified mathematical modeling and zone scheduling for multi-directional multi-car elevators. IEEE 4th Glob. Conf. Consum. Electron.; 2015. p. 61–4. https://doi.org/10.1109/ GCCE.2015.7398572. 2015.
- [71] Feng H, Zhang W, Xiao C, Xu X, Zhang S. Performance comparison and optimization of permanent magnet flux switching linear motor for ropless elevator system. 2021 13th Int. Symp. Linear Drives Ind. Appl. 2021:1–5. https://doi.org/10.1109/LDIA49489.2021.9505742.
- [72] Cesarz M. Connecting the three dimensions of urban transportation. Int J High-Rise Build 2020;9:81–5. https://doi.org/10.21022/IJHRB.2020.9.1.81.
- [73] Appunn R, Frantzheld J, Jetter M, Löser F. MULTI® rope-less elevator demonstrator at test tower Rottweil. Transp Syst Technol 2018;4:80–9. https://doi.org/10.17816/transsyst20184380-89.
- [74] Architecture & Design. World's first rope-free elevator wins Gold for thyssenkrupp at Edison Awards. Archit Des; 2017. https://www. architectureanddesign.com.au/news/world-s-first-rope-free-elevator-winsthyssenkrupp.
- [75] EMPORIS. Provider of international skyscraper and high-rise building data!. 2022. https://www.emporis.com/.
- [76] Council on Tall Buildings and Uban Habitat. Advancing Sustainable Vertical Urbanism. https://www.ctbuh.org/?redirect=true; 2022. CTBUH.
- [77] International Institute for Applied Systems Analysis. Regions. IIASA. 2022. https://docs.messageix.org/projects/global/en/latest/overview/spatial.html.